

Pipe, Standard Ordering Code

Pipe Size (DN)	Max	Normal	Transitional	Min	Max Reading	Min Reading	Remark
	m³/h				m³		
15	3	1.50	0.12	0.03	99999.999	0.001	The minimum reading can be set according to user requirements.
20	5	2.50	0.20	0.05			
25	7	3.50	0.28	0.07			
32	12	6	0.48	0.12			
40	20	10	0.80	0.20			
50	56	28	1.76	0.50	999999999	1	
65	100	50	3	0.84			
80	145	72	4.52	1.27			
100	230	110	7.07	1.69			
125	360	180	11.04	2.65			
150	500	250	15.90	3.82			
200	900	450	28.26	5.65			
250	1400	700	44.16	8.83			
300	2000	1000	50.87	12.72			
350	2800	1400	70	17.31			
400	3600	1800	90	22.61			
450	4500	2250	110	28.61			
500	5600	2800	140	35.33			
600	8100	4050	200	50.87			
700	11000	5500	275	69.24			
800	14400	7200	360	90.43			
900	18300	9150	457	114.45			
1000	22600	11300	565	141.30			

